

Laboratory approved by the Ministry for the Interior
JO of February 10, 2007OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE
Of A MATERIAL ENVISAGED IN ARTICLE 5
DECREE OF November 21, 2002N° **CM - 17 - P - 021**

et 1 annexe de 4 pages.

Page 1

Valid 5 years as from mardi 7 mars 2017

Material presents by : **VEROTEX AG**Bahnhofstr. 38
95236 STAMMBACHTrade mark: **ARTICLE 3208**

Summary description

Kind of textile support textile enduit

Composition support : 100% polyester (woven fabric) + enduction : 100% acrylique

Mass per unit area 220 g/m²

Tickness 0,30mm

Color Tous coloris

Nature of the test : Electrical burner test
Flame persistence flame
Dripping test
Artificial ageingClassification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) Not limited

Usual term Walls hung covering, sheers, curtains,...

Cleaning conditions Not washable with water and not cleanable

Taking into account the criteria resulting from the tests annexed described in the test report N°FE 17-0087-0473 et FE 17-0044-0245

This official report attests only characteristics of the sample submitted for testing and does not prejudge similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.


NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test.

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006)"

Champs-sur-Marne, le mercredi 31 mai 2017

Technicienne d'essais
du Laboratoire FeuSiège social Clotilde ETIEMVRE
10 rue Galilée
77420 Champs-sur-Marne
Tél + 33 (0)1 72 84 97 84
www.fcba.fr
Siret 775 680 903 00132
APE 7219 Z
Code TVA CEE : FR 14 775 680 903

Only the french version remains valide



Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement